

steady.error Steady-state error for unity feedback systems

It is uncommon for a feedback system to be truly "unity." However nonunity feedback systems can be re-written and evaluated in terms of unity feedback counterparts.¹ For this reason, we will focus on unity feedback systems. First we recall the final value theorem. Let $f(t)$ be a function of time that has a "final value" $f(\infty) = \lim_{t \rightarrow \infty} f(t)$. Then, from the Laplace transform of $f(t)$, $F(s)$, the final value is $f(\infty) = \lim_{s \rightarrow 0} sF(s)$. Let's consider the unity feedback system of Figure error.1 with command R , controller transfer function G_1 , plant transfer function G_2 , and error E . Recall that we call $e(t)$ or (its Laplace transform) $E(s)$ the error. We want to know the steady-state error, which, from the final value theorem, is

$$e(\infty) = \lim_{s \rightarrow 0} sE(s). \quad (1)$$

Now all we need is to express $E(s)$ in more convenient terms. For the analysis that follows, we combine the controller and plant: $G(s) = G_1(s)G_2(s)$. From the block diagram, we can develop the transfer function from the command R to the error E .

Equation 2 error transfer function

$$\begin{aligned} E(s) &= R(s) - Y(s) \\ &= R(s) - G(s)E(s) \\ E(s) &= \frac{1}{1+G(s)} R(s) \end{aligned}$$

Given a specific command R and forward-path transfer function G , we could take inverse Laplace transform of $E(s)$ to find $e(t)$ and take the limit. However, it is much easier to use the final value theorem:

$$\begin{aligned} e(\infty) &= \lim_{s \rightarrow 0} sE(s) \\ &= \lim_{s \rightarrow 0} \frac{s}{1+G(s)} R(s) \end{aligned}$$

This last expression is the best we can do without a specific command R . Three different commands are typically considered canonical. The first is now developed in detail, and the results of the other two are given below. First, consider a unit step command, which has Laplace transform $R(s) = 1/s$.

$$\begin{aligned} e(\infty) &= \lim_{s \rightarrow 0} \frac{1}{1+G(s)} \frac{1}{s} \\ &= \lim_{s \rightarrow 0} \frac{1}{s(1+G(s))} \\ &= \frac{1}{1+K_p} \end{aligned}$$

where we let $K_p = \lim_{s \rightarrow 0} G(s)$. We call K_p the position constant. If K_p is large, the steady-state error is small. If K_p is infinitely large, the steady-state error is zero. If K_p is small, the steady-state error is a finite constant. The form of $G(s)$ has implications for K_p . $G(s)$ has a factor $1/s^n$ where n is some nonnegative integer. Since we are concerned about what happens to $G(s)$ when we take its limit as $s \rightarrow 0$, this factor is of particular importance. If $n > 0$, $K_p = \lim_{s \rightarrow 0} G(s) = \infty$. We call the transfer function $1/s$ an integrator, which is the inverse of the transfer function s , the differentiator. We needn't solve for E explicitly, then. All we need to know is the command R and the number of integrators n in the forward-path transfer function $G(s)$ (we call this the system type). The steady-state error for other commands and system type can be derived in the same manner. The results for the canonical inputs are shown in Table error.1.

¹ For more details, see N. S. Nise (2011, Section 7.6).



Figure error.1: unity feedback block diagram with controller $G_1(s)$ and plant $G_2(s)$.

Example steady.error-1

Let a system have forward-path transfer function

$$G(s) = \frac{10(s+3)(s+4)}{s(s+1)(s^2+2s+5)}$$

For commands $r_1(t) = 2u_s(t)$, $r_2(t) = 6tu_s(t)$, and $r_3(t) = 7t^2u_s(t)$, what are the steady-state errors?

$$r_1 \quad K_p = \lim_{s \rightarrow 0} \frac{10(s+3)(s+4)}{s(s+1)(s^2+2s+5)} = \infty \quad e(\infty) = 0$$

$$r_2 \quad K_v = \lim_{s \rightarrow 0} s \frac{10(s+3)(s+4)}{s(s+1)(s^2+2s+5)} = \frac{10(3)(4)}{1(5)} = \frac{120}{5}$$

$$e(\infty) = \frac{1}{K_v} = \frac{5}{120} \quad \text{unit ramp}$$

$$e(\infty) = 6 \frac{5}{120} = \frac{5}{20} = \frac{1}{4} \quad \text{for } 6tu_s(t)$$

$$r_3 \quad K_a = \lim_{s \rightarrow 0} s^2 \frac{10(s+3)(s+4)}{s(s+1)(s^2+2s+5)} = 0 \quad e(\infty) = \frac{1}{K_a} = \frac{1}{0} = \infty$$

Table error.1: the static error constants and steady-state error for canonical commands $r_1(t)$ and systems of Types 0, 1, 2, and ν_1 (the general case). Note that the faster the command changes, the more integrators are required for finite or zero steady-state error.

$r(t)$	Type ν		Type 0		Type 1		Type 2	
	error const.	$e(\infty)$	error const.	$e(\infty)$	error const.	$e(\infty)$	error const.	$e(\infty)$
$u_s(t)$	$K_p = \lim_{s \rightarrow 0} G(s)$	$\frac{1}{1+K_p}$	K_p	$\frac{1}{1+K_p}$	∞	0	∞	0
$tu_s(t)$	$K_v = \lim_{s \rightarrow 0} sG(s)$	$\frac{1}{K_v}$						
$\frac{1}{2}t^2u_s(t)$	$K_a = \lim_{s \rightarrow 0} s^2G(s)$	$\frac{1}{K_a}$						